

1. ID code of the product-type:

RGG multi cable transit system

2. Intended use:

Fire stopping modular cable penetration sealing system

3. Manufacturer:

MCT Brattberg AB

Lyckeåborg

37192 Karlskrona, Sweden

4. Authorised representative:

N/A

5. System acc. AVCP:

System 1

6 a. Harmonized standard:

N/A

6 b. European Assessment Document

EAD No. 350454-00-1104

European Technical Assessment

ETA-16/0475

Technical Assessment Body

TZÚS- Technical and Test Institute for Construction Prague

Notified body

1812

7. Declaration of performance:

Features	Performance	Harmonized techn. Spec.
Reaction to fire	Class E	According to EN 13501-1
Resistance to fire	EI 60 & E 120	According to EN 13501-2
	EI 90 & EI 120 (Max cable size \varnothing 21mm)	
Durability and serviceability	Use category X for the system with components made of stainless steel or galvanized mild steel. Use category Z ₂ for the system with components made of coated mild steel or aluminium.	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of MCT Brattberg AB

Karlskrona 2019-04-24



Technical Engineer
Johan Fagerberg



Quality Manager
Magnus Larsen